

**Planning Commission
 Interdepartmental Comment Form
 Planning Commission Meeting Date: May 11, 2026**

Please review the plans for your department's area of concern and respond back by 4/30/2026

<i>PC office use only</i>	<i>Sent to:</i>	<i>Date Returned</i>
Inspections	<input checked="" type="checkbox"/>	_____
Engineering	<input checked="" type="checkbox"/>	_____
Police	<input checked="" type="checkbox"/>	_____
Fire	<input checked="" type="checkbox"/>	_____
Service	<input checked="" type="checkbox"/>	_____
Forester	<input checked="" type="checkbox"/>	_____
Finance	<input type="checkbox"/>	_____

Project Name: Cuyahoga Hardwoods Subdivision preliminary plan
 Parcel #: 21316034 to 037, 21616013, 21316018
 Street Address: 26814 Center Ridge
 Date received: 4/8/2026
 Date distributed: 4/8/2026

Name	Michael Freeman	Date	4/13/2026
Title	Assistant Chief	Department	Fire

Please provide your comments (if you have no comments you do not need to respond):

- Any subdivision or street proposed to contain more than twenty-five dwellings thereon, or any street or extension thereof, proposed to exceed 1,000 feet in length, shall have a minimum of two permanent means of access, one from each direction. Such permanent means of access must be a dedicated public street(s) constructed to the street standards of Section 1129.08 and have at least two intersections with one or more major or secondary street(s). WCO 1127.04 (3)