

**Planning Commission  
 Interdepartmental Comment Form  
 Planning Commission Meeting Date: June 1, 2026**

**Please review the plans for your department's area of concern and respond back by 5/21/2026**

<i>PC office use only</i>	<i>Sent to:</i>	<i>Date Returned</i>
Inspections	<input checked="" type="checkbox"/>	_____
Engineering	<input checked="" type="checkbox"/>	_____
Police	<input checked="" type="checkbox"/>	_____
Fire	<input checked="" type="checkbox"/>	_____
Service	<input checked="" type="checkbox"/>	_____
Forester	<input checked="" type="checkbox"/>	_____
Finance	<input type="checkbox"/>	_____

Project Name: Faraj Plaza development plan  
 Parcel #: 21230015  
 Street Address: 27210 Center Ridge Rd.  
 Date received: 5/13/2026  
 Date distributed: 5/14/2026

Name	Click here to enter text.	Date	Click here to enter a date.
Title	Click here to enter text.	Department	Choose an item.

Please provide your comments (if you have no comments you do not need to respond):

1. Approved signs shall be provided for fire apparatus access roads/fire lanes to identify such roads or prohibit the obstruction thereof. 2025 OFC chapter 5
  - Please place no parking sign (s) to identify the southwest curb from the building to the dumpster as a fire lane.
2. A Knox Box (approved locking key box) is required to be installed in an approved location determined by the Fire Department and 2025 OFC Section 506
  - \*at each separate tenant space if separate retail spaces.
3. Emergency Responder Radio coverage shall be provided in all new buildings in accordance with 2025 OFC 510.