

**Planning Commission
 Interdepartmental Comment Form
 Planning Commission Meeting Date: June 1, 2026**

Please review the plans for your department's area of concern and respond back by 5/21/2026

<i>PC office use only</i>	<i>Sent to:</i>	<i>Date Returned</i>
Inspections	<input checked="" type="checkbox"/>	_____
Engineering	<input checked="" type="checkbox"/>	_____
Police	<input checked="" type="checkbox"/>	_____
Fire	<input checked="" type="checkbox"/>	_____
Service	<input checked="" type="checkbox"/>	_____
Forester	<input checked="" type="checkbox"/>	_____
Finance	<input type="checkbox"/>	_____

Project Name: Cahoon Nursery development plan
 Parcel #: 21213071
 Street Address: 27630 Detroit Rd.
 Date received: 4/29/2026
 Date distributed: 4/29/2026

Name	Michael Freeman	Date	5/5/2026
Title	Assistant Chief	Department	Fire

Please provide your comments (if you have no comments you do not need to respond):

Cahoon

1. Type V construction is not allowed within the city of Westlake. WCO 1303.06
2. A Knox Box (approved locking key box) is required to be installed in an approved location determined by the Fire Department 2017 OFC Section 506. Order the box at www.knoxbox.com.
3. New and existing buildings shall have approved address numbers, building numbers or approved building identification placed in a position that is plainly legible and visible from the street or road fronting the property. These numbers shall contrast with their background. Address numbers shall be Arabic numerals or alphabet letters. Numbers shall be a minimum of 4 inches (102mm) high with a minimum stroke width of 0.5 inch (12.7 mm). 2017 OFC Section 505.1