

Planning Commission

Interdepartmental Comment Form

Planning Commission Meeting Date: September 14, 2026

Please review the plans for your department's area of concern and respond back by
Click here to enter a date.

PC office use only *Sent to:* *Date Returned*

Inspections	☒	_____
Engineering	☒	_____
Police	☒	_____
Fire	☒	_____
Service	☒	_____
Forester	☒	_____
Finance	☐	_____

Project Name: Maruti Hotel Group Inc. development plan
Parcel #: 21308018
Street Address: 25050-25054 Sperry Rd.
Date received: 8/10/2026
Date distributed: 8/11/2026

Name	Michael Freeman	Date	8/11/2026
Title	Assistant Chief	Department	Fire

Please provide your comments (if you have no comments you do not need to respond):

1. To comply with the Ohio Fire Code inspection and testing requirements, will private hydrants be serviced and inspected annually by the occupant of the parcel in which it is located?
2. Private fire hydrants are to be painted Rust Oleum yellow with white tops. 2025 507.5.7 hydrant color