



B-1)

EXTERIOR/ OUTDOORS

I	WIRING	
I-F: FEED	TO ELECTRICAL FEED.	
I-P: PRIMARY	12awg FEED IN 1/2"Ø CONDUIT & CONNECTORS.	
I-S: SECONDARY	U.L. APPROVED LOW VOLTAGE CLASS II WIRING.	
I-C: CONNECTOR	U.L. APPROVED LOW VOLTAGE CLASS II CONNECTOR.	
I-J: J-BOX	ALL CONNECTIONS TO BE IN ELECTRICAL BOXES.	
I-D: DISCONNECT	120V DISCONNECT SWITCH. LOCATION T.B.D.	
WIRE NOTE:	WIRES TO BE TERMINATED w UL LISTED FASTENERS.	
J	POWER SUPPLY	
TYPE:	LOW VOLTAGE U.L. APPROVED LED POWER SUPPLY HOUSE IN FRONT ACCESS WEATHERPROOF LED P/S BOX	
VOLTAGE:	120V	
M	MOUNTING	
M-1:	REQ'D. BLOCKING BY OTHERS.	
M-2:	EXISTING FASCIA.	
M-3:	(4) 3/8"Ø MECH. FASTENER THRU (E) PLATE, V.I.F.	
M-4:	PAN-HEAD SCREW.	
COLOR/ FINISH:	FINISH HEAD TO MATCH.	
W	WEEP HOLE	
TYPE:	1/4"Ø HOLE w/ LIGHT-BLOCKING COVER	
	MIN. QTY.: ONE (1).	

